

## Classification

Number	22-002900-PR03 (NW-K09-09-en-01)
Owner	Finotech Switzerland AG Im Dörfli 14b 8700 Küsnacht Switzerland
Product	two-component sealant
Designation	Shipping name: Finotech® SQ-50
Details	Sealant: Material <b>Silicone</b> ; manufacturer <b>Finotech Switzerland AG</b> colour <b>black</b> <b>Substrate 1:</b> Designation <b>CLR-6mm</b> ; Material <b>Float glass</b> ; manufacturer <b>Taiwan Glass Group Changjiang Co. Ltd.</b> <b>Substrate 2:</b> Material <b>anodized Aluminium</b> ; colour <b>E6/C0</b> manufacturer and coater <b>Suzhou Lopsking Aluminum Co., Ltd;</b>
Special features	-/-
Result **)	Determination of the adhesive and physical properties of an sealant and product identification according to ETAG 002-1



**Requirements: fulfilled**

\*\*) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

## Basis \*)

EOTA-ETAG 002-1-3rd Amendment:2012-05

\*) and corresponding national versions (e.g. DIN EN)

Test report: 22-002900-PR03 PB-K09-09-en-01

## Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

## Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies. The document may only be published in full.

ift Rosenheim

19.01.2024



Michael Freinberger, Dipl.-Ing. (FH)  
Head of Testing Department  
Material Testing

Monika Hutter, Dipl.-Ing. (FH)  
Operating Testing Officer  
Material Testing

Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: A1C-F209E